



## केन्द्रीय रेल विद्युतीकरण संगठन

Central Organisation for Railway Electrification  
1-Nawab Yusuf Road, Civil Lines, Prayagraj-211001  
e-mail: ceehq.core@gmail.com, dyceemp@gmail.com

No: ELCORE/MP/Vendor app. Process

Date: 24/01/2020

To,

**As per mailing list enclosed**

**विषय/Sub:** Supply of angles, channels, flats & rounds for fabrication of Galvanized Steel Structures for OHE & TSS.

**संदर्भ/Ref:** This office letter of even no. dated 13.12.2018, 30.01.2019 & 07.01.2020

\*\*\*\*\*

The competent authority has approved purchase of the following 32 items of sizes of angles, channels flats & rounds from any of the CORE approved re-rollers or from BIS licensed suppliers subject to submission of necessary documents for proof of traceability.

	<b>Angles</b>	<b>Use</b>
1	35x35x6	Fencing panel and anti climbing device
2	40x30x5	TSS lattice tower/ lattice beam
3	40x40x5	Chair (3050)
4	40x40x6	Portal super mast
5	45x45x5	Tower T1 & T2, anti -climbing device for SP/SSP, Fencing panel/anti climbing device, TSS lattice tower/ lattice beam
6	45x45x6	DA- I & DA-II, Fencing panel/anti climbing device
7	50x50x5	Mounting Structure for TSS
8	100x100x6	Cross bracing angle (S-134)
9	100x100x12	Dwarf mast attachment (DMA)
10	125x75x8	Guide tube fittings
11	110x110x8	
12	150x75x10	Anchor assemblies
13	150x150x10	
14	150x150x12	
15	130x130x10	SPL Portals structures
16	130x130x12	

	<b>Channels</b>	<b>Use</b>
1	75x40	Multiple Cantilever Extension chair (3100)
2	300x90	TTC Structures for High Rise OHE
3	400x100	GU

Contd... 2

	Flats	Use		Rounds	Use
1	40x6	TSS anchor beam S-122, S-117, S-113	1	10 mm	Portal super mast
2	50x6	Number plat clamps	2	16 mm	N & B type portals
3	50x8	Isolator Guide Ring	3	20 mm	O, R & G portals
4	65x10	TTU& NK	4	22 mm	SPL Portals STRs
5	75x8	O portal	5	32 mm	Earthing Bus
6	75x10	OK	6	36 mm	
			7	40 mm	

**The above approval is valid up to 31.12.2021.**

As approved earlier, the stage inspection of above 32 (Thirty Two) items will be carried out by RITES at vendor's premises.

*(Upendra Kumar)*  
*24.01.2020*

Dy. Chief Electrical Engineer/MP  
For Chief Administrative Officer, CORE/ALD

**Copy for information to:**

1. CPD/RE/ADI, DNR, JP, LKO, NJP, SBC, SC, UMB
2. GGM/I/CR([crinspn@rites.com](mailto:crinspn@rites.com)), ER([erinspn@rites.com](mailto:erinspn@rites.com)), NR([nrinspn@rites.com](mailto:nrinspn@rites.com)), WR([wrinspn@rites.com](mailto:wrinspn@rites.com)), SR([srinspn@rites.com](mailto:srinspn@rites.com))